



E1 CHILLED WATER DEMOLITION FLOW DIAGRAM
 MD801 SCALE: NO SCALE SHOWN

GENERAL NOTES

1. REFER TO M-001 FOR MECHANICAL ABBREVIATIONS, LEGEND, SYMBOLS, AND GENERAL NOTES.
2. REFER TO M-701 FOR CONTROLS ABBREVIATIONS, SYMBOL LEGEND, AND GENERAL NOTES.
3. COMPONENTS SHOWN HALF-TONE ON THIS DRAWING ARE ITEMS TO REMAIN; DASHED COMPONENTS ARE TO BE DEMOLISHED.
4. DEMOLITION FLOW DIAGRAM IS SCHEMATIC IN NATURE. SUBCONTRACTOR MUST FIELD VERIFY CONDITIONS.
5. CAP EXISTING TO REMAIN OBSOLETE, ABANDONED BRANCH LINES DOWNSTREAM OF EXISTING BRANCH ISOLATION VALVE.
6. DEMOLITION WORK SHALL BE ACCOMPLISHED WITHOUT DRAINING FULL SYSTEM. FREEZING PIPE OR USING HOT TAP PIPE PLUG INSERTION SOLUTION IS ACCEPTABLE.
7. EXISTING CHILLED WATER MAKEUP WATER CONNECTION, PRV, BACKFLOW PREVENTER, AND EXPANSION TANK MUST REMAIN CONNECTED TO CHILLED WATER SYSTEM WHILE TEMPORARY CHILLER IS IN OPERATION.

8. COMMUNICATE VALVE FUNCTION TO CONSTRUCTION MANAGER AND RECEIVE APPROVAL FOR LOCKOUT-TAGOUT PRIOR TO DEMOLITION START.

Sheet Title	MECHANICAL CHILLED WATER DEMOLITION FLOW DIAGRAM
Dwg. No.	PLM2021-0432-0011D
Sht. No.	MD801