



PROVIDE LIGHT HAZARD WET SPRINKLER SYSTEM

4TH FLOOR PLAN - NORTH - FIRE PROTECTION
SCALE: 1/8"=1'-0"

- KEY NOTES:**
- ① COMBINATION STAND PIPE.
 - ② 2" TEST DRAIN.
 - ③ PROVIDE SPRINKLER ZONE VALVE ASSEMBLY AND HOSE VALVE IN RECESSED CABINET AT MID STAIR LANDING.
 - ④ PROVIDE RECESSED FIRE HOSE CABINET WITH HOSE VALVE.
 - ⑤ MODIFY EXISTING WET SPRINKLER SYSTEM TO PROVIDE COMPLETE COVERAGE.

