© 2007 FKP Architects, Inc. All rights reserved. No part of this document may be reproduced or utilized in any form without prior written authorization of FKP Architects, Inc.

RFI 2099 12" Round duct, CSFD and associated grille to remain

RFI #5650

RFI #4510.1 Return air temperature sensor to replace T-stat.

RFI #4510 For conflict between T stat and electrical signage, it is suggested to provide space sensors, to be mounted on wall or ceilings.

RFI #4837 Return air temp sensor in lieu of t stat.

RFI #4962.1 Move diffusers just North of gridline 10 to allow revised soffit framing.

LEVEL 2 MECHANICAL PLAN AREA - E

DESIGN KEY NOTES

1. DDC CONTROL PANEL (PER CONTRACT & PROJECT REQUIREMENTS)
2. ALL WELDED SS CONSTRUCTION WITH 2 HR. FIRE RATED DUCT SHAFT.
3. PROVIDE 3-WAY VALVE FOR REHEAT COIL.
4. STERILIZER LOCATED ON THE THIRD FLOOR. STEAM LINE SUPPLY AND CONDENSATE RETURN SERVING THE STERILIZERS FROM LEVEL 2.
5. COOLING ONLY CV BOX (#1)

EXAMPLE - FIRE/SMOKE RATING

Suites Shell Space

Finish Floor Elevation=143.30'

KEY PLAN

NIC

A1 Key Plan N.T.S.

DESIGN KEY NOTES

KEY PLAN

FKP Architects

ARCHITECT OF RECORD

"Architect of Record signature line only; this drawing was not prepared under the direct supervision of the Architect of Record. The direct responsibility for preparation of this sheet lies with its corresponding professional stamp and signature. The signature of the Architect of Record in general responsible charge of the project is provided as required by Title 24, Part 1, Section 7-115 (a)".

ARCHITECT - PAUL C. GLORIOD

CONSULTANT

TMAD TAYLOR & GAINES
- STRUCTURAL
- MECHANICAL
- ELECTRICAL
- CIVIL

100 South Anaheim Boulevard, Suite 150
Anaheim, California 92805
Phone: 714.490.5555 Fax: 714.490.5560
Project No. 2305-163-07

REGISTERED PROFESSIONAL ENGINEER GERARD MAZLOOM No. 22257 Exp. 12/31/11 MECHANICAL STATE OF CALIFORNIA

Changes on these drawings do not consist of materially altered changes to approved drawings and don't require a change order.
OSHPD review ACO _____
OSHPD review FLSO _____
OSHPD review DSE _____

REVISIONS

68	02/01/2011	ASI #57
61	03/01/2011	CHANGE ORDER #134

APPROVAL

Office of Statewide Health Planning & Development (OSHPD) PLANS REVIEWED IN ACCORDANCE WITH THE REQUIREMENTS OF TITLE 24 & APPROVED 7-8-11

CHANGE ORDER# _____
INSTRUCTION BULLETIN# _____
DEFERRED APPROVALS# _____
ADDENDUM# _____

PROJECT NAME

CHILDREN'S HOSPITAL OF ORANGE COUNTY
455 S. Main St.
Orange, CA 92868-3874

TOWER II

RECEIVED
July 12 2011
McCARTHY

CHOC SM HOSPITAL

PROJECT NUMBER

12011.00
Increment #7
12002-00

OSHPD - PROJECT NUMBER

IL 072072-30

ISSUE

OSHPD PERMIT

DATE

01/27/2010

SCALE

1/4" = 1' - 0"

DRAWING TITLE

LEVEL 2 MECHANICAL PLAN AREA - E

DRAWING NUMBER

M3.2E

T:\23CAD\2305\2305-163-07\VIC-7_JM-P\M3_2E.DWG
6/9/2011
MERNANDEZ